



Translation
1st Supplement

(Supplement in accordance with Directive 94/9/EC Annex III number 6)


**to the EC-Type Examination Certificate
DMT 03 ATEX E 029**

Equipment: Photoelectric Sensor type * 92/3 * Ex
Manufacturer: Leuze electronic GmbH & Co.
Address: D - 73277 Owen-Teck

Description

The Photoelectric Sensor type * 92/3 * Ex meets as well category 2D.

The new marking is as follows:

 **II 2G EEx ia IIC T6**
II 2D Ex iaD 21 T 80 °C

The Essential Health and Safety Requirements of the modified equipment are assured by compliance with.

EN 50014:1997+A1-A2	General requirements
EN 50020:2002	Intrinsic Safety 'i'
prEN 61241-0:2002	Dust explosion protection General requirements
3IH/160/NP (IEC 61241-11)	Intrinsically safe apparatus 'iD'

Test and assessment report

BVS PP 03.2015 EG as of 26.01.2004

EXAM BBG Prüf- und Zertifizier GmbH
Bochum, dated 26. January 2004

Signed: Wittler

Certification body

Signed: Schumann

Special services unit

We confirm the correctness of the translation from the German original.
In the case of arbitration only the German wording shall be valid and binding.

44809 Bochum, 26.01.2004
BVS-Hk/Mi A 20030912

EXAM BBG Prüf- und Zertifizier GmbH



Certification body



Special services unit