ZERTIFIKAT ◆ CERTIFICATE ◆ 認証書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT

Product Service

CERTIFICATE

No. Z10 16 02 68636 018

Holder of Certificate: **Leuze electronic GmbH + Co.KG**
In der Braike 1
73277 Owen/Teck
GERMANY

Factory(ies): 70507

Certification Mark:

Product: **Safety components**
Safety switching device

Model(s): **MSI-SR4**
MSI-SR4B-01
MSI-SR4B-02

Parameters:

Supply Voltage:	24V AC/DC ±20%
Operating temperature:	0°C...+55°C
Storage temperature:	-25°C...+70°C
IP code (housing):	IP40
IP code (clamp):	IP20

Tested according to:
2006/42/EC
EN 61496-1:2013 (Type 4)
EN 61508-1:2010 (SIL 3)
EN 61508-2:2010 (SIL 3)
EN 61508-4:2010 (SIL 3)
EN ISO 13849-1:2006/AC:2009 (Cat.4, PL e)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: LF82519T

Valid until: 2021-02-22

Date, 2016-02-23

(Christian Dirmeier)

685331

Page 1 of 1